

Notice

Since the production of this document, Solar Gard has been purchased by Saint-Gobain Performance Plastics Corporation. Solar Gard is now a subsidiary of Saint-Gobain. All references within this document to Bekaert, Bekaert Specialty Films or Bekaert Specialty Films LLC, including but not limited to legal notes, copy and or copyrights are null and void. All rights and responsibilities expressed or written within this document have been transferred from Bekaert Specialty Films, LLC to Saint-Gobain.

The company name in the following report could not be retroactively changed from Bekaert to Solar Gard. The integrity of the product represented in the test has not changed and the results for this product are still valid. As the test is update the new report will reflect the Solar Gard name.

Saint-Gobain Performance Plastics
4540 Viewridge Avenue
San Diego, CA 92123 USA
Tel: 877 345 3478
E-mail: info@solargard.com
www.solargard.com





BESCHUSSAMT MELLRICHSTADT

Zertifikat

Certificate

09Z327B01

Inhaber des Zertifikates

Holder of the certificate

Bekaert Specialty Films LLC
4540 Viewridge Avenue
CA 92123 San Diego
USA

**Prüfung der durchwurfhemmenden Eigenschaften einer Verglasung nach
DIN EN 356**

Test of the resistance against manual attack of glazing according to DIN EN 356

Stand der Richtlinie

Version of the guideline

Februar 2000

Hersteller

Manufacturer

Bekaert Specialty Films LLC

Auftraggeber

Applicant

Bruxsafol Folien GmbH
Thüringenstraße 2
D-97762 Hammelburg-Westheim

Prüfgegenstand

Sample

Isolierglasscheibe
Insulated Glass Unit

Probenbezeichnung

Reference

Solar Gard Armorcoat 14 mil / P2A / Insulated Glass
Unit - Annealed Glass

Prüfdatum

Test Date

15. September 2009

Detaillieregebnisse siehe**Prüfbericht Nr.**

Detailed results see test report No.

09G327B01

Das vorgelegte Prüfmuster erfüllte die Prüfbedingungen nach
The sample met the requirements according to

DIN EN 356

und erhält folgende Widerstandsklasse:
and has obtained the following classification:

P2A

Dieses Zertifikat besitzt eine Gültigkeit von zehn Jahren ab dem Tag der Prüfung und ist nur mit Unterschrift und Dienstsiegel gültig. Die auszugsweise Weitergabe dieses Zertifikates ist nur mit Genehmigung des Beschussamtes Mellrichstadt erlaubt.

This Certificate is valid for ten years beginning with the day of testing and is only valid with signature and official seal. The duplication in extracts only is allowed with approval of the Beschussamt Mellrichstadt.

Beschussamt Mellrichstadt, 17. September 2009

Willner



Beschussamt Mellrichstadt (Mellrichstadt Ballistics Agency) • Lohstr. 5 • 97638 Mellrichstadt
Telefon +49-9776-7050-0 • Telefax +49-9776-5457 • poststelle@ba-mel.bayern.de • Germany